

Thank you for selecting a DuctSox System. This guide will be helpful for the installation of a Cable System. Sections of fabric will be labeled, assembled, bagged, and boxed for shipping. More complicated systems will include a CAD detail of the system identifying what is in each package.

NOTE: The DuctSox cable attachment (Glider) is built for 1/8" (3mm) cable only.

Overview

Inventory

The first step on any installation project is to read through this guide thoroughly and review the components that need to be installed. The best way to do this is to review the drawings of the project while reading the guide, including the CAD detail if applicable.

Shipping/Receiving

In some cases the DuctSox support system is delivered to the job site ahead of the DuctSox fabric sections. Depending on the size of a project or order, a DuctSox system will be shipped by common courier in a single brown box or several boxes. Larger orders will be shipped in crates by a common freight courier. Each DuctSox length should be packaged into individual plastic bags and labeled according to size and number of pieces. Other markings or labeling may also be incorporated for larger or more complicated systems. Be sure you have determined all boxes are accounted for.

Unpacking

Inspect shipment carefully and make sure all pieces are accounted for. Account for everything by emptying the box and examining all contents. Note any missing or damaged pieces listed on the Bill of Lading.


Labeling

Each DuctSox section will be marked with the size and section number either inside the belt of the inlet or on a tag inside the DuctSox near the zipper. The marking shall be the diameter, section length and total length. If custom labeling has been used, locate an identification sheet that will be included with the delivery.

Equipment Required:

- Drill
- Level
- Tape measure
- Marker or pencil
- Wrenches for cable clamps and eye bolts (5/16" and 9/16")
- Flat (standard) screwdriver
- Cable cutter

Component Details



Installation Steps

1. Review materials in box, including the CAD drawing and installed location of the DuctSox
2. Prepare metal inlet collar for fabric connection
3. Mark placement and install cable. (1 Row, 2 Row, and 3 Row Style)
4. Install and assemble DuctSox components
5. Start up AHU
6. Balance airflow


Step 1

Review materials in box, including the CAD drawing and installed location of the DuctSox. READ INSTRUCTIONS THOROUGHLY BEFORE BEGINNING.

Step 2

Prepare metal inlet collar for fabric connection.


- Confirm inlet air supply location.
- Confirm inlet air supply size.
- DuctSox inlets are manufactured 1/2" (12mm) larger than specified to fit over metal inlet collar.
- Metal collar length should be 6"–10" (150 to 250cm) for secure fabric attachment.
- Edge Guard (provided) should be installed on the edge of the metal collar to reduce fabric wear from the metal edge.




Step 3

Mark Placement and Install Cable. Step 3 is broken into three types of suspension points: 1 Row, 2 Row, and 3 Row. One job may use multiple styles.


Step 3 – 1 Row Style



Step 3 – 2 Row Style
10 and 2 O'clock



Step 3 – 3 Row Style
10, 2, and 12 O'clock



The following details are used for ALL styles.

Type 1 and Type 2 Kits

Type 1 and Type 2 kits are for straight runs of cable, 100 feet (30500mm) or less for Type 1 and Type 2 for over 100 feet (30500mm). These kits include one 6" (153mm) turnbuckle (two for Type 2), two eyebolts, two cable thimbles, and four cable clamps.

Eye bolts must be fastened into the structure of the building by others (this could include knee braces).

Cable is fastened directly to an eyebolt with a thimble and two cable clamps. Take the cable end and thread two cable clamps onto it. Now hook the thimble onto the eyebolt. Next, thread the cable onto the thimble and through the eyebolts (cable clamps are still on the cable). Now thread the cable back into the cable clamps and tighten them.



Cable is then fastened directly to the turnbuckle with a thimble and two cable clamps. Slack in the cable is taken up by the turnbuckle. If cable is still too loose after tightening the turnbuckle, loosen the cable, re-fasten cable to turnbuckle at a tighter position, and re-tighten the turnbuckle. Do not over-tighten the turnbuckle, we recommend no more than 100 lbs (445 Newtons) of tensile force.

Intermediate Support Cable

Installed every 30 feet (9150mm) or less to keep the DuctSox installed at a consistent elevation (reduces sag of the cable).

Standard



Pools





Step 3 – 1 Row Style

Determine placement of cable (both cable path and elevation). The cable must be mounted 1.5" (38mm) above the 12:00 location of the DuctSox. Intermediate Cable supports are spaced no more than 30ft (9150mm).

T's

There should be roughly 12" (305mm) from sidewall of DuctSox to the closest edge of any knee-bracing. Structure too close to the main run may cause premature failure due to abrasion from the structure. NOTE: Offset distance of branch knee-brace from main trunk is approximately half of the main trunk diameter plus 12" (305mm).



Elbows

Extended straps on heels of elbows are provided for support to cable suspension (Figure A). Vertical elbows are also supported by extended straps (Figure B).




Figure A





Figure B

Step 3 – 2 Row Style

Determine placement of cable (both cable path and elevation). The cable must be located “A” inches apart and “B” inches below the 12:00 location of the DuctSox (match this up to the chart and the drawing). Intermediate cable supports are spaced no more than 30 ft (9150mm).

Diameter (inches)	A	B
12	10.83	1.63
14	12.56	2.13
16	14.29	2.63
18	16.02	3.13
20	17.75	3.63
22	19.49	4.13
24	21.22	4.63
26	22.95	5.13
28	24.68	5.63
30	26.41	6.13
32	28.15	6.63
34	29.88	7.13
36	31.61	7.63
38	33.34	8.13
40	35.07	8.63
42	36.81	9.13
44	38.54	9.63
46	40.27	10.13
48	42.00	10.63
50	43.73	11.13
52	45.47	11.63
54	47.20	12.13
56	48.93	12.63
58	50.66	13.13
60	52.39	13.63
62	54.13	14.13
64	55.86	14.63
66	57.59	15.13
68	59.32	15.63
70	61.05	16.13
72	62.79	16.63
74	64.52	17.13
76	66.25	17.63
78	67.98	18.13
80	69.72	18.63
82	71.45	19.13
84	73.18	19.63


Diameter (mm)	A	B
305	275	41
356	319	54
406	363	67
457	407	79
508	451	92
559	495	105
610	539	117
660	583	130
711	627	143
762	671	156
813	715	168
864	759	181
914	803	194
965	847	206
1016	891	219
1067	935	232
1118	979	244
1168	1023	257
1219	1067	270
1270	1111	283
1321	1155	295
1372	1199	308
1422	1243	321
1473	1287	333
1524	1331	346
1575	1375	359
1626	1419	371
1676	1463	384
1727	1507	397
1778	1551	410
1829	1595	422
1880	1639	435
1930	1683	448
1981	1727	460
2032	1771	473
2083	1815	486
2134	1859	498



T's

There should be roughly 12" (305mm) from sidewall of DuctSox to the closest edge of any knee-bracing. Structure too close to the main run may cause premature failure due to abrasion from the structure.

NOTE: Offset distance of branch knee-brace from main trunk is approximately half of the main trunk diameter plus 12" (305mm).



Elbows

Extended straps on heels of elbows are provided for support to cable suspension (Figure A). Vertical elbows are also supported by extended straps (Figure B).




Figure A





Figure B

Step 3 – 3 Row Style (10, 2, and 12)

Determine placement of cable (both cable path and elevation). The cable must be located “A” inches apart and “B” inches or 1.5 inches below the 12:00 location of the DuctSox (match this up to the chart and the drawing). Intermediate cable supports are spaced no more than 30 ft (9150mm).


Diameter (inches)	A	B
12	10.83	1.63
14	12.56	2.13
16	14.29	2.63
18	16.02	3.13
20	17.75	3.63
22	19.49	4.13
24	21.22	4.63
26	22.95	5.13
28	24.68	5.63
30	26.41	6.13
32	28.15	6.63
34	29.88	7.13
36	31.61	7.63
38	33.34	8.13
40	35.07	8.63
42	36.81	9.13
44	38.54	9.63
46	40.27	10.13
48	42.00	10.63
50	43.73	11.13
52	45.47	11.63
54	47.20	12.13
56	48.93	12.63
58	50.66	13.13
60	52.39	13.63
62	54.13	14.13
64	55.86	14.63
66	57.59	15.13
68	59.32	15.63
70	61.05	16.13
72	62.79	16.63
74	64.52	17.13
76	66.25	17.63
78	67.98	18.13
80	69.72	18.63
82	71.45	19.13
84	73.18	19.63

Diameter (mm)	A	B
305	275	41
356	319	54
406	363	67
457	407	79
508	451	92
559	495	105
610	539	117
660	583	130
711	627	143
762	671	156
813	715	168
864	759	181
914	803	194
965	847	206
1016	891	219
1067	935	232
1118	979	244
1168	1023	257
1219	1067	270
1270	1111	283
1321	1155	295
1372	1199	308
1422	1243	321
1473	1287	333
1524	1331	346
1575	1375	359
1626	1419	371
1676	1463	384
1727	1507	397
1778	1551	410
1829	1595	422
1880	1639	435
1930	1683	448
1981	1727	460
2032	1771	473
2083	1815	486
2134	1859	498



T's

There should be roughly 12" (305mm) from sidewall of DuctSox to start of the branch track. Track too close to the main run may cause premature failure due to abrasion from the track. Support around fabric fittings may require additional track supports. NOTE: Offset distance of branch U-Track from main trunk is approximately half of the main trunk diameter plus 12" (305mm).



Elbows

Extended straps on heels of elbows are provided for support to cable suspension (Figure A). Vertical elbows are also supported by extended straps (Figure B).





Figure A

Figure B



Step 4

Install DuctSox Fabric. DuctSox Inlet must be attached to the metal collar using screws (not included) through plastic patches on the Inlet Belt. Be sure to locate the zipper start and seam at the 12:00 orientation for proper alignment.

Twist and snap the Glider attachments of the DuctSox onto the cable (pliers may be helpful for installation and removal of Gliders). Unzip fittings and slide them in place independently of the straight sections. Cable Stops are installed at the Endcap Glider, at the Inlet Glider, and at each Glider immediately adjacent to all fittings. Leave them installed loose until Step 5 is complete. Close all zipper connections before moving to Step 5.



The Cable Stop is used to keep sections of DuctSox from moving lengthwise on the cable. They also are used to put a slight tension on straight sections of DuctSox (straight sections may consist of more than one zippered section of DuctSox). Nuts are tightened to lock the stop at locations where Gliders are to be locked in place (see Step 5).



Step 5

Start Up AHU. Turn on the AHU and inflate the DuctSox System. Check all Gliders and sections to ensure system is inflating properly. If required, move Gliders to eliminate puckering at binding locations. If lengths do not fit properly, double check all field measurements and compare to drawings. If all measurements are correct, contact your DuctSox factory rep to discuss options.

Once system is properly adjusted, inflate the system, pull the last Glider in each straight section (including straight sections between fittings), and secure tension using Track Stop Screws. Also, be sure to install a Track Stop Screw into the U-Track at the Endcap Glider, at the Inlet Glider, and at each Glider immediately adjacent to all fittings.

The Track Stop Screw is used to keep sections of DuctSox from moving lengthwise in the U-track. They also are used to put a slight tension on straight sections of DuctSox (straight sections may consist of more than one zippered section of DuctSox). The screw is tightened into the bottom channel to lock the stop at locations where Gliders are to be locked in place.

If the system includes elbows or T's, secure Gliders before and after these fittings. Failure to install DuctSox Systems correctly may void warranty.

Step 6

Air Balancing. System must be balanced to design CFM and static pressure immediately after installation. Most DuctSox Systems include a zipper at the inlet location for easy access to monitor flow.

If the fabric is fluttering after balancing, please contact your factory rep immediately. Solutions to the fluttering include adjusting the Adjustable Flow Device (AFD), adding AFDs, or other solutions that would result in a less turbulent airflow.

Laundering Instructions

Sedona-Xm, TufTex, Verona, DuraTex, Microbe-X, Rx, and Stat-X fabrics:

- Remove the DuctSox fabric from your system, being sure to unzip all sections. Take care in recording where each section was installed.
- Turn soiled side out, soak in cold water for 30 minutes.
- Wash cold, gentle cycle.
- Rinse thoroughly (repeat cycle if water/DuctSox still soiled).
- Drip dry or no-heat tumble dry.



If any questions arise regarding the installation of your Cable System, contact us.

866-382-8769 or 563-588-5300

DUCTSOX[®]
Textile Air Dispersion Products

9866 Kapp Court ■ Peosta, IA 52068
Ph: 866-382-8769 or 563-588-5300 ■ Fax: 563-588-5330
www.ductsox.com